

ORDINANCE NO. 32-22

AN ORDINANCE AUTHORIZING, AFFIRMING AND RATIFYING THE MAYOR ENTERING INTO EMERGENCY CONTRACTS FOR THE REPAIR TO THE AMBERWOOD PARKWAY SANITARY SEWER LIFT STATION OF THE CITY OF ASHLAND, OHIO; OBTAINING FORMAL ADVERTISING AND BIDDING AND DECLARING AN EMERGENCY.

WHEREAS, the sanitary sewer lift station at Amberwood Parkway is in immediate need of emergency repairs in order to continue in operation; and

WHEREAS, this Council desires to authorize, affirm and ratify the entering of such contracts as determined necessary to address the serious public health issues created by the failure of the aforesaid sanitary sewer lift station; and

WHEREAS, time being of the essence regarding the public health and safety consequences of the malfunctioning lift station, this Council finds it necessary to obviate formal advertising and bidding; and

WHEREAS, this Ordinance is hereby declared to be an emergency measure immediately necessary for the preservation of the public peace, property, health, safety and welfare and for the further reason that the specified repair work was immediately needed in order to provide for the continued efficient and effective operation of the Division of the Waste Water of said City of Ashland, Ohio, now therefore,

BE IT ORDAINED by the Council of the City of Ashland, State of Ohio, 5 members thereto concurring:

SECTION 1. That the Mayor be, and is hereby, authorized and directed to enter into such contracts as may be necessary for the purchase of emergency repairs for the Waste Water lift station at Amberwood Parkway of the City of Ashland, Ohio, and that such contracts already entered are hereby ratified and affirmed.

Emergency Repairs of the Amberwood Parkway Lift Station not to exceed \$90,000.00.

Estimated Repairs Proposed Are Attached and Marked "Exhibit A," hereto and made a part hereof.

SECTION 2. That this Council finds that such repairs were immediately needed due to the serious risk to public health and safety and that, for said reason and time being of the essence, the above-referenced contracts for repair are authorized and ratified and approved obviating formal advertising and bidding.

SECTION 3. That the money for said repairs will be from the Waste Water Fund 611 in a method as determined by the Director of Finance.

SECTION 4. That for reason that the repairs herein specified are immediately needed in order to provide for the continued efficient and effective operation of the Division of Waste Water Division of the City of Ashland, this Ordinance is hereby declared to be an emergency measure immediately needed for the preservation of the public peace, property, health, safety and welfare of said City of Ashland, Ohio.

SECTION 5. That this Ordinance shall take effect and be in force from and after its passage by Council and approval pursuant to Section 12 of the Charter of the City of Ashland, Ohio.

Passed: 3 May, 2022

Attest: Teresa Santino
Teresa Santino, Clerk of Council

Approved as to form and correctness:

Richard P. Wolfe II
Richard P. Wolfe II, Director of Law

Steve Workman
Steve Workman, President of Council

Approved: Matt Miller
Matt Miller, Mayor

Date: 3 May, 2022

EXHIBIT A-1



2246 Port Centre
Medina OH 44256
United States
(234) 312-3511

Quotation

Date: 04/13/2022
Expires: 05/13/2022
Quote #: 50070
Sales Rep: Lantz, Brandon
 blantz@pumpsystemsllc.com
 (330) 607-0847

Project Title:
Amberwood Rehab

Bill To
 City of Ashland, Water Treatment Plant
 206 Claremont Ave.
 Ashland OH 44805
 United States

Ship To
 Ashland Water Treatment
 1996 E. Main Street
 Ashland OH 44805
 United States

Prepared For: Sherry Fair

Quantity	Description
	Phase 1 (wet well interior)...
2	Hydromatic S4HRC750M6-2, 7.5HP, 3450RPM, 208/3/60, 5" Vortex Impeller
2	50ft Cords
2	4" MTM Lift out System to include: Discharge Elbow, Upper Bracket, Sealing Flange Assembly w/ Hardware
2	SS Intermediate Rail Bracket
64	CHAIN, 1/4" PROOF COIL STAINLESS STEEL, T-316, WLL 2000 LBS. ---2 LENGTHS AT 30' and a 1' leg
6	Shackle, 5/16" 316SST Screw Pin Wide D-Shackle, SSDS312 (1300 WLL)
1	Concrete Cutting and Breaking will straight cut the flattop opening larger to increase the pump access - create a 30" x 50" if needed
1	Halliday hatch: 034054M-C, 34" x 54" Flood Tight Cover (Q36865)
3	4" Schedule 80 PVC Pipe, 20' length in the wet well only
2	4" Schedule 80 PVC 90 Degree Bend, Soc in the wet well only
8	4" Schedule 80 PVC Van Stone Flange, 2-Piece in the wet well only
2	4" Coupler epoxy coated body with 304SS band clamps in the wet well only
0.5	UNISTRUT, 1.625" SQUARE, SST X 20 FT. LG. in the wet well only
2	Unistrut, Open 45-Degree Bend, 4-Hole, SST in the wet well only
4	Wej-it Stud Anchor: 3/8"x3-3/4", 18-8 SST in the wet well only
4	Washer, Standard Flat; 3/8"x7/8", 18-8 SST in the wet well only
4	Nut, Hex Finish; 3/8"-16, 18-8 SST in the wet well only
4	Screw, Cap; 3/8"-16 X 1-1/2" LG., 18-8 SST in the wet well only
1	32 OZ, LO-VOC, PVC Primer in the wet well only

Subtotal: \$ 56,713.04
Shipping: \$ 1,100.00
Total: \$ 57,813.04

Applicable Tax Not Included in Total

Quote Acceptance

Signing this proposal in the space below constitutes your order and our agreement to pricing, term and conditions contained herein. Please furnish us a confirming purchase order at your earliest convenience.

Company Name: _____
 Signature: _____
 PO#: _____

Printed Name: _____
 Date: _____

EXHIBIT A-2



2246 Port Centre
 Medina OH 44256
 United States
 (234) 312-3511

Quotation

Date: 04/13/2022
 Expires: 05/13/2022
 Quote #: 50070
 Sales Rep: Lantz, Brandon
 blantz@pumpsystemsllc.com

Project Title:
 Amberwood Rehab

Quantity	Description
1	32 OZ, LO-VOC, PVC Cement in the wet well only
6	2" Schedule40 316SST Pipe x 20 ft long
48	Screw, Cap; 5/8"-11 X 3" LG., 18-8 SST
48	Nut, Hex Finish; 5/8"-11, 18-8 SST
48	Washer, Standard Flat; 5/8"x1-1/2", 18-8 SST
8	Wej-it Stud Anchor: 1/2"x3-3/4", 18-8 SST (pump bases)
16	Wej-it Stud Anchor: 3/8"x3-3/4", 18-8 SST (float bracket and hatch)
1	CS-102 to seal the hatch to the precast flattop
1	Pump Station Service - 4 days to complete
544	Per Mile Rate - Roundtrip (portal to portal)
1	Confined Space Entry Permit Phase 2 (valve vault interior)...
1	Internal DI items... (2) 4" check valves w/olw (3) plug valves with levers (3) 4" DI 90's (1) 4" DI cross (2) 4" Smith Blair 912's (12) 4" flange gaskets
2	S9204SS pipe stands with 2" SS extension pipe
1	4" Flange x Male coupler, Domestic Aluminum
1	4" Cap, Domestic Aluminum
96	Screw, Cap; 5/8"-11 X 3" LG., 18-8 SST.
96	Nut, Hex Finish; 5/8"-11, 18-8 SST
96	Washer, Standard Flat; 5/8"x1-1/2", 18-8 SST
1	Pump Station Service - 2.5 days to complete the valve vault
340	Per Mile Rate - Roundtrip (portal to portal)
1	Confined Space Entry Permit

Pump Systems converted the wet well interior pipe and fittings to PVC80 from DI and changed the pumps.
 Also, I'll make another trip out to the site confirming the hatch opening and what we need to do, if anything, with Brandon. That may save you around \$1400 if Concrete Cutting isn't needed!
 Pump Systems not responsible for any pipe or fitting disposal. We will remove the pumps from the site since those will

Subtotal: \$ 56,713.04
 Shipping: \$ 1,100.00
 Total: \$ 57,813.04

Applicable Tax Not Included in Total

Quote Acceptance

Signing this proposal in the space below constitutes your order and our agreement to pricing, term and conditions contained herein. Please furnish us a confirming purchase order at your earliest convenience.

Company Name: _____
 Signature: _____
 PO#: _____

Printed Name: _____
 Date: _____

EXHIBIT A-3



2246 Port Centre
Medina OH 44256
United States
(234) 312-3511

Quotation

Date: 04/13/2022
Expires: 05/13/2022
Quote #: 50070
Sales Rep: Lantz, Brandon
blantz@pumpsystemsllc.com

Project Title:
Amberwood Rehab

Quantity	Description
	fit in the truck without cutting if you so chose.

Subtotal: \$ 56,713.04
Shipping: \$ 1,100.00
Total: \$ 57,813.04

Applicable Tax Not Included in Total

Quote Acceptance

Signing this proposal in the space below constitutes your order and our agreement to pricing, term and conditions contained herein. Please furnish us a confirming purchase order at your earliest convenience.

Company Name: _____
Signature: _____
PO#: _____

Printed Name: _____
Date: _____